

## **Mandatory Language for Surface Water Treatment Technique Violation**

### **SURFACE WATER TREATMENT TECHNIQUE:**

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. You do not need to use an alternative water supply.

The **UPPER LEON RIVER MWD**, PWS ID **TX0470015**, failed to meet the minimum treatment technique requirements for the month of **FEBRUARY 2021**. Specifically, our water system had

#### **Violation List:**

- More than 5% of the combined filter effluent turbidity readings were above 0.3 NTU for the month.
- Low Disinfection Contact Time (CT) for more than four consecutive hours.

The violations listed above are for Plant ID **TP14780** and occurred over a 3-day period as a result of Winter Storm Uri.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact CARROLL G. ABBEY at (254) 879-2258.

Posted /Delivered on: 05/27/2021

## **Mandatory Language for Surface Water Treatment Technique Violation**

### **SURFACE WATER TREATMENT TECHNIQUE:**

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. You do not need to use an alternative water supply.

The **UPPER LEON RIVER MWD**, PWS ID **TX0470015**, failed to meet the minimum treatment technique requirements for the month of **FEBRUARY 2021**. Specifically, our water system had

#### **Violation List:**

- Low Disinfection Contact Time (CT) for more than four consecutive hours.

The violations listed above are for Plant ID **TP412212** and occurred as a result of Winter Storm Uri.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact CARROLL G. ABBEY at (254) 879-2258.

Posted /Delivered on: 05/27/2021